



ADVANCED SOIL ENGINEERING

GEOTECHNICAL CONSULTING ENGINEERS
CONCRETE AND MATERIAL TESTING LABORATORIES

P.O. BOX 1286
ISABELA, P.R. 00662

TEL : (787) 830-0366
FAX: (787) 830-8962

October 31, 2007

Mundo Real Quarry
P.O. Box 818
Aguada, P.R. 00602

SUBJECT : SPECIFIC GRAVITY (FINE AGGREGATE) ANALYSIS

Project : Mundo Real Quarry
Isabela, Puerto Rico

Sample secured and transported by : Mundo Real Quarry personnel

Receive date of test sample : October 25, 2007

Date tests were performed : October 30, 2007

Standard test method used : ASTM D 854

Sample description : Pale yellow silty sand
trace limestone fragments
(Arena Space Maker)

Sample Location : Mundo Real Quarry
Isabela, Puerto Rico

Specific Gravity : 2.63

Test : Oven Dried

Respectfully submitted,

ADVANCED SOIL ENGINEERING

NELSON MUÑOZ, P. E.